

SEPTIC TANK/COLLECTION WELL

SPECIFICATIONS:

Concrete 40mpa comp strength
 At 28 days, reinforced with F62
 Mesh or equivalent to comply
 With A.S. 1546
 All tanks conform to
 Australian Standards Mark
 Certification
 License No. SMK1473



Aussie Precast Products

Manufacturers of Septic Tanks & Collection Wells
 11229 Princes Highway, Cobargo NSW 2550
 Ph: (02) 64938327 Fax: (02) 64938338
 Email: beachline@bigpond.com

SEPTIC TANK: 3,550 LITRES

COLLECTION WELL: 3,600 LITRES

Name.....	
Lot.....DP.....	
Street.....	
Locality.....	
Shire.....	
Wastes to be Connected:	
All Wastes	
WC (4.5 ltr flush)	
WC (13.6 ltr flush)	
Basin	
Bath/Shower	
Kitchen Sink	
Laundry	

LID

